



YOUR PUMP'S BEST ASSET

9608 Wellington Rd. #23, Erin, ON, N0B 1T0
 tel: 519-833-9597 fax: 519-833-2651
 toll free: 877-599-PUMP (7867)
 email: Roy@ThePumpGuy.ca

W.O.# _____

INSPECTION DATE: _____

CUSTOMER _____

JOB LOCATION: _____

MODEL: _____

SPEC: _____

S/N _____

LEGEND: = PASS / = FAIL / N/A = NOT APPLICABLE

LUBRICATION SYSTEM

- Oil Level
- Leaks
- Heater
- Oil Sample Taken

COOLING SYSTEM

- Coolant Level
- Hoses
- Block Heater
- Leaks
- Antifreeze Protection Reading _____

FUEL SYSTEM

- Fuel Level
- Flex Connections
- Transfer Pump
- Level Gauge
- Leaks
- Pipework
- Water Content

INDUCTION/EXHAUSTS SYSTEM

- Air Filter(s)
- Flex Connections
- Hoses
- Pipework
- Muffler Drain
- Turbo Charger Rotor
- Turbo Pre-Lube

STARTIG SYSTEM

- Electrolyte Level
- Cables
- Terminals
- Corrosion
- Battery Charger

RADIATOR/HEAT

EXCHANGER SYSTEM

- Belt Tension
- Pulley Grooves
- Lubrication
- Cleanliness
- Pipework
- Corrosion Plugs
- Solenoid Valve
- Thermostatic Valve
- Strainer
- Louvre Operation
- Leaks

INSTALLATION

- Mounts
- Sub-Base
- Flex Connections
- Cleanliness

ALTERNATOR

- Connections
- Cables
- Bearings
- Lubrication
- Coupling
- Alignment
- Rotor/Stator
- Collector Ring

CONTROL PANEL

- Brushes
- Metering
- Lights
- Horn/Buzzer
- Switches
- Fuses
- Cleanliness
- Connections
- Protection System
- Hourmeter Reading

PROTECTION SYSTEM

- Low Oil Pressure
- High Water Temperature
- Overspeed
- Overcrank
- Low Battery Voltage

_____ PSI
 _____ F
 _____ rpm
 _____ secs
 _____ VDC

Crank Disconnect _____ rpm
 Block Heater Temperature _____ F
 Radiator Cap Setting _____ PSI
 Cooling System Pressure tested _____ min at _____ psi
 Voltage Drop (cranking cold) _____ VDC _____ VDCNL
 Load Test Batteries _____ secs at _____ CCA

COMMENTS

CUSTOMER REPRESENTATIVE: (print & sign) _____

THE PUMP GUY TECHNICIAN: (print & sign) _____